

**178 NAC 2 Attachment 3 - Pool Water Quality Log Sheet**

Pool Name:		City:	
Operator Name:		Month:	

**Record Before Opening and Every 4 Hours**

	Date							
Pool Residual Cl: 2.0-10.0 ppm Br: 2.0-18.0 ppm	Time							
	Level							
	Time							
	Level							
	Time							
	Level							
	Time							
	Level							
	Time							
	Level							
	pH (7.2-7.8)	Time						
		Level						
Time								
Level								
Time								
Level								
Time								
Level								
Time								
Level								
Time								
Level								
Amount of Chemicals Added, Equipment Maintenance (filters backwashed, etc.)								
Sampler's Initials								

Record Weekly	Date						
Combined Chlorine (≤ 0.5 ppm)	Time						
	Level						
Cyanuric Acid (≤ 50 ppm)	Time						
	Level						
Total Alkalinity (> 80 ppm)	Time						
	Level						

\_\_\_\_\_  
Nebraska Swimming Pool Operator's Signature