

Title 178 NAC 2 Attachment 4 - Spa Water Quality Log Sheet

Spa Name:		City:	
Operator Name:		Month:	

Record Before Opening and Every 4 Hours

	Date						
Spa Residual Cl: 3.0-10.0 ppm Br: 4.0-18.0 ppm	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
pH (7.2-7.8)	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
Spa Temperature (≤ 104° F)	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
	Time						
	Level						
Amount of Chemicals Added, Equipment Maintenance (filters backwashed, etc.)							
Sampler's Initials							

Record Weekly	Date						
Combined Chlorine (≤ 0.5 ppm)	Time						
	Level						
Cyanuric Acid (≤ 50 ppm)	Time						
	Level						
Total Alkalinity (> 80 ppm)	Time						
	Level						

Nebraska Swimming Pool Operator's Signature