

# Total Coliform Repeat Monitoring Sample Site Selection Procedure

The \_\_\_\_\_  
(Name of Public Water System)  
will use the following procedure when selecting sample sites to be used for Total Coliform Repeat Monitoring.

1. Preference will be given to a site that is located within five service connections on either side (up and down) of the location of the coliform positive sample (original).
2. If a site is not suitable within five connections up and/or down from original site location, a site will be selected from a location that is as near as possible to the original location that is representative of that area of the distribution system.
3. All repeat sites selected will be evaluated to ensure that they meet the system's criteria for a representative site. That is, the site must meet the same physical/environmental conditions of the routine sample sites of the system.

\_\_\_\_\_  
Mayor/Chairperson

\_\_\_\_\_  
Date

\_\_\_\_\_  
Water System Representative

\_\_\_\_\_  
Date